



We help ideas meet the real world

# Compliance Statement

No. 2015-084

## Screened Channel, Class E<sub>A</sub>

### Company

PCnet Wire & Cable Co., Ltd.  
No. 381 , Sec 1 Jhongping RD  
Hukou Township  
Hsinchu County, 303  
Taiwan R.O.C

### Channel Identification (4 connector model)

#### Horizontal Cable:

PCnet Data Connx 10G Category 6A BULK Cable

#### Cords:

PCnet Data Connx 10G Category 6A Patch Cord

#### Wall Outlet:

PCnet Data Connx 10G Keystone Jack

#### Patch Panel:

PCnet Data Connx 10G 24 Port Patch Panel

### Generic cabling standards - Class E<sub>A</sub> Channel requirements

- ISO/IEC 11801:2011 (Ed. 2.2)
- EN 50173-1:2011
- EN 50173-2:2007, including amendment A1:2010
- ANSI/TIA-568-C.2:2009

### Technical report

DELTA-T210036, DANAK-19/14936

### EC Cabling product ID

5007

### CS valid until

1 March 2016

This product has been tested by DELTA EC Cabling Group and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that DELTA EC Cabling performs a sample test of the product once a year.

Hørsholm, 10 February 2015

Lars Lindskov Pedersen  
Test Manager

Claude Videt  
Project Manager

### DELTA

Venlighedsvej 4  
2970 Hørsholm  
Denmark

Tel. +45 72 19 40 00  
Fax +45 72 19 40 01  
[www.madebydelta.com/cable](http://www.madebydelta.com/cable)

